

DEPARTMENT OF TRANSPORTATION - District 4 Toll Bridge Program

333 Burma Rd.

Oakland, CA 94607

(510) 622-5660, (510) 286-0550 fax

*Flex your power
Be energy efficient!*

July 09, 2008

Contract No. 04-0120F4

04-SF-80-13.2 / 13.9

Self-Anchored Suspension Bridge

Letter No. 05.03.01-002345

Michael Flowers
Project Executive
American Bridge/Fluor, A JV
375 Burma Road
Oakland, CA 94607

Dear Michael Flowers,

Submittal 646 - Tower - External Struts Type 2 & 3A - Lift 4

The Department has completed review of Submittal ABF-SUB-000646R00, "Tower - External Struts Type 2 and 3A - Lift 4," dated March 26, 2008. Pursuant to the Comment Resolution Meeting (CRM) of July 3, 2008, the submittal is "Returned for Correction," as shown on the attached drawings and as outlined by the following comments:

CATEGORY A:

1. It is understood that the Contractor has chosen Optional Detail B for the fit up at ZPMC. Revise the length of the flange splice plate per Note 10 of Contract Plan Sheet 566/1204 and Optional Detail B of 567/1204.

CATEGORY B:

1. As discussed in the CRM, comment A1 above, with respect to the flange splice plates, will apply to the previous external strut submittals for Lifts 1, 2 and 3. Provide updated shop drawings for review in the respective strut submittals.

If you have any questions, please contact Gary Lai at the Working Drawing Campus.

Sincerely,

A handwritten signature in blue ink that reads 'Gary Purcell'.

GARY PURSELL
Resident Engineer

Attachment

cc: Rick Morrow
Gary Lai
Mark Woods
file: 05.03.01, 55.0646